

N65928.AR.002624
NTC ORLANDO
5090.3a

LETTER REGARDING REGULATORY REVIEW AND CONCURRENCE WITH TANK
CLOSURE STATUS NTC ORLANDO FL
3/12/1998
FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Department of Environmental Protection

FILE COPYLawton Chiles
GovernorTwin Towers Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400Virginia B. Wetherell
Secretary

March 12, 1998

Mr. Nick Ugolini
Code 184 (PVC)
Southern Division
Naval Facilities Engineering Command
2155 Eagle Drive
P.O. Box 190010
North Charleston, South Carolina 29419-9010

RE: Tank Closure Assessment Reports for Buildings Nos. 351, 354, 356, 358, 361, 363, 364, 366, 369, 371, 375, and 384, Naval Training Center, Orlando, Florida


Dear Mr. Ugolini:

I have completed the technical review of the above referenced documents submitted by the Navy Public Work Center (PWC) Pensacola dated December 1997 (received January 21, 1998). The conclusions and recommendations for clean tank closure at the above referenced buildings are approved other than for Building 354 which will require a Site Assessment report due to benzo(a)pyrene exceeding the groundwater cleanup target level.

Also, in the letter submitted by PWC Pensacola, it indicated TCARS were included for Buildings 106, 131, 218, 2010, 2035, 2122, and 7182. These TCARS were not submitted; therefore they cannot receive clean closure at this time.

If I can be of any further assistance with this matter, please contact me at (904) 921-9989.

Sincerely,


John W. Mitchell
Remedial Project Manager

cc: Wayne Hansel, Navy SouthDiv
Lt. Gary Whipple, NTC Orlando
Nancy Rodriguez, USEPA Region IV
John Kaiser, ABB-ES, Orlando
Bob Cohose, Bechtel, Knoxville
Steve McCoy, Brown and Root, Oak Ridge
Kurt R. Gies, PWC Pensacola
Bill Bostwick, FDEP Central District

cc: J. Kaiser
M. Alonso
S. Donelick

TJB 3JJC JJCESN ESN